


Report of Analysis

Name:	Water System Solutions Design Inc PO Box 180 Watertown, CT 06795-0180	Sample ID#:	293454
Sample Date:	8/17/2022 12:30 PM	Sample Type:	Drinking Water
Receipt Date:	8/17/2022 1:22 PM	Sample Source:	Sample tap 1A
Report Date:	8/31/2022	Sampler:	RB
Sample Site:	Weston School - Municipal - CT1570132		

Parameter	Sample Result	Units	Limits	Method	RL	Analysis Date / Time
Organic Compounds						
PerFluoroButaneSulfonic Acid	ND	ng/L	No Limit Set	EPA 537	1.34	8/19/2022 11:40
PerFluoroHeptanoic Acid	ND	ng/L	No Limit Set	EPA 537	1.34	8/19/2022 11:40
PerFluoroHexaneSulfonic Acid	ND	ng/L	49	EPA 537	1.34	8/19/2022 11:40
PerFluoroHexanoic Acid	ND	ng/L	No Limit Set	EPA 537	1.34	8/19/2022 11:40
PerFluoroNonanoic Acid	ND	ng/L	12	EPA 537	1.34	8/19/2022 11:40
PerFluoroOctaneSulfonic Acid	ND	ng/L	10	EPA 537	1.34	8/19/2022 11:40
PerFluoroOctanoic Acid	ND	ng/L	16	EPA 537	1.34	8/19/2022 11:40
PerFluoroButaneSulfonic Acid(Field blank)	ND	ng/L	No Limit Set	EPA 537	1.34	8/19/2022 11:40
PerFluoroHeptanoic Acid(Field blank)	ND	ng/L	No Limit Set	EPA 537	1.34	8/19/2022 11:40
PerFluoroHexaneSulfonic Acid(Field blank)	ND	ng/L	49	EPA 537	1.34	8/19/2022 11:40
PerFluoroHexanoic Acid(Field blank)	ND	ng/L	No Limit Set	EPA 537	1.34	8/19/2022 11:40
PerFluoroNonanoic Acid(Field blank)	ND	ng/L	12	EPA 537	1.34	8/19/2022 11:40
PerFluoroOctaneSulfonic Acid(Field blank)	ND	ng/L	10	EPA 537	1.34	8/19/2022 11:40
PerFluoroOctanoic Acid(Field blank)	ND	ng/L	16	EPA 537	1.34	8/19/2022 11:40

ND = Not Detected
 * = Above Specified Limit

Report Approved by:  _____ CT Lic PH-0787 NY Lic 11706

Lab Director

AquaEnvLab.com
 YorkLab.com
 203 270 9973

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.