

Report of Analysis

Water System Solutions Design Inc Name:

PO Box 180

Watertown, CT 06795-0180

Sample Date: 8/17/2022 12:40 PM **Receipt Date:** 8/17/2022 1:22 PM

8/31/2022 **Report Date:**

Sample Site: Weston School - Municipal - CT1570132 Sample ID#: 293455

Sample Type: Drinking Water Sample Source: Sample tap 3A

Sampler: RB

Parameter	Sample Result	Units	Limits	Method	RL	Analysis Date /
						Time
Organic Compounds						
PerFluoroButaneSulfonic Acid	ND	ng/L	No Limit Set	EPA 537	1.34	8/19/2022 11:40
PerFluoroHeptanoic Acid	ND	ng/L	No Limit Set	EPA 537	1.34	8/19/2022 11:40
PerFluoroHexaneSulfonic Acid	ND	ng/L	49	EPA 537	1.34	8/19/2022 11:40
					1	1
PerFluoroHexanoic Acid	ND	ng/L	No Limit Set	EPA 537	1.34	8/19/2022 11:40
PerFluoroNonanoic Acid	ND	ng/L	12	EPA 537	1.34	8/19/2022 11:40
PerFluoroOctaneSulfonic Acid	ND	ng/L	10	EPA 537	1.34	8/19/2022 11:40
PerFluoroOctanoic Acid	ND	ng/L	16	EPA 537	1.34	8/19/2022 11:40

ND = Not Detected* = Above Specified Limit

Report Approved by:

Lab Director

CT Lic PH-0787

NY Lic 11706

AquaEnvLab.com YorkLab.com 203 270 9973

Analytical results relate to the samples as received at the laboratory. Report shall not be reproduced except in its entirety without written approval from the laboratory.